



ig,



v "Ω

TÜV(TÜV Rheinland)
 (SIL) SIL2, SC3 IEC 61508
 EU: I (M1) [Ex ia Ma] I
 II (1)G [Ex ia Ga] IIC
 II (1)D [Ex ia Da] C
 II 3(1)G Ex ec nC [ia Ga] IIC T4 Gc
 IECEx: [Ex ia Ma]
 [Ex ia Ga] IIC
 [Ex ia Da] C
 Ex ec nC [ia Ga] IIC T4 Gc
 (Um) 250V

NPEXA-K51	(1 2)	
Uo=10.5V,	Io=11.3mA,	Po=29.7mW
IIC χ	I	Lo=51.05mH
C(II B) χ	I	Lo=468.7mH
IIA χ	I	Lo=1025mH
I χ	I	Lo=1739mH
NPEXA-K511	(1 2)	
Uo=10.5V,	Io=11.3mA,	Po=29.7mW
IIC χ	I	Lo=37.33mH
C(II B) χ	I	Lo=455mH
IIA χ	I	Lo=1011mH
I χ	I	Lo=1725mH